



NOTES:

1. ALL PIPING, FITTINGS, VALVES, ETC., SHOWN IN BROKEN LINES ARE BY OTHERS.
2. WHEN USING A WATER METER, THERE MUST BE A MINIMUM AMOUNT OF STRAIGHT PIPE BEFORE AND AFTER THE SENSOR. REFER TO INSTALLATION INSTRUCTIONS FOR DETAILS.

DO NOT SCALE DRAWING TOLERANCES: ±1/8" UNLESS OTHERWISE NOTED				
Let.	Change	By	App	Date
A	NEW RELEASE	KMR	TMJ	1/8/2009

Culligan®
ENGINEERED SYSTEMS
 NORTHBROOK, ILLINOIS

PRINT AND BILL OF MATERIAL ARE NOT TO BE USED WITHOUT THE WRITTEN CONSENT OF CULLIGAN INTERNATIONAL CO.

NAME CSM-150-2CD DUPLEX ALT SKID MOUNT		
DETAILED BY: KMR 1/6/2009	APP. BY:	SHEET 1 OF 1
REF. NO. SNO0348A	PART NO. SPO02787	